



# TEST REPORT

**REPORT NUMBER: 140829012SHJ-BP-1**  
ORIGINAL ISSUE DATE: December 1, 2014

## EVALUATION CENTER

Intertek Testing Services Ltd., Shanghai  
Plant 7, No. 6958 Daye Road, Fengxian District, Shanghai  
China 201405

## RENDERED TO

**ZHEJIANG JIAHUI DOORS CO., LTD.**  
**NO. 6 JIAHUI ROAD GUMASHAN INDUSTRIAL ZONE WANGZHAI TOWN**  
**WUYI**

## PRODUCT EVALUATED

Double Leaves Swing Steel Fire Door Assembly

## EVALUATION PROPERTY

Fire Resistance

**Report of Testing Double Leaves Swing Steel Fire Door Assembly for compliance with the applicable requirements of the following criteria: BS 476-22:1987 Fire Tests on Building Materials and Structures – Part 22: Methods for Determination of the Fire Resistance of Non-loadbearing Elements of Construction.**

*"This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program."*

# 1 Table of Contents

---

|      |                                                  |    |
|------|--------------------------------------------------|----|
| 1    | Table of Contents .....                          | 2  |
| 2    | Introduction .....                               | 3  |
| 3    | Test Samples .....                               | 3  |
| 3.1. | SAMPLE SELECTION .....                           | 3  |
| 3.2. | SAMPLE AND ASSEMBLY DESCRIPTION.....             | 3  |
| 4    | Testing and Evaluation Methods .....             | 4  |
| 5    | Testing and Evaluation Results .....             | 4  |
| 5.1. | INTEGRITY.....                                   | 4  |
| 5.2. | INSULATION .....                                 | 4  |
| 6    | Conclusion .....                                 | 5  |
| 7    | Appendix A: Fire Door Assembly Drawings .....    | 6  |
| 8    | Appendix B: Hardware Drawings.....               | 7  |
| 9    | Appendix C: Test Wall Construction Drawing ..... | 9  |
| 10   | Appendix D: Test Measurement Data.....           | 10 |
| 11   | Appendix E: Test Data .....                      | 13 |
| 12   | Appendix F: Test Photographs .....               | 18 |
| 13   | Revision Page .....                              | 22 |

## 2 Introduction

---

Intertek has conducted an evaluation for ZHEJIANG JIAHUI DOORS CO., LTD. to determine the fire resistance characteristics of the Double Leaves Swing Steel Fire Door Assembly. This evaluation began on November 20, 2014 and was completed on December 1, 2014. The test was conducted on November 24, 2014.

The test was conducted in accordance with BS 476-22:1987 "Fire Tests on Building Materials and Structures – Part 22: Methods for Determination of the Fire Resistance of Non-loadbearing Elements of Construction, Section 6: Determination of the Fire Resistance of Fully Insulated Doorsets and Shutter Assemblies".

## 3 Test Samples

---

### 3.1. SAMPLE SELECTION

Samples were submitted to Intertek directly from the client. Samples were not independently selected for testing. Samples were received at the Evaluation Center on November 20, 2014.

### 3.2. SAMPLE AND ASSEMBLY DESCRIPTION

|                  |                                                                                                  |                                                                                                                                         |
|------------------|--------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------|
| Door             | Type                                                                                             | Double Leaves Single Acting Swing Steel Fire Door Assembly                                                                              |
|                  | Nominal Size                                                                                     | Inactive leaf: 1055.5 mm wide by 2232 mm high by 50 mm thick<br>Active leaf: 1055.5 mm wide by 2232 mm high by 50 mm thick              |
|                  | Surface Panel                                                                                    | 1.0 mm Galvanized Steel                                                                                                                 |
|                  | Core                                                                                             | Material: Perlite<br>Density: 340 kg/m <sup>3</sup> ±10%                                                                                |
|                  | Stiffener                                                                                        | 1.0 mm Galvanized Steel, rectangle cross section<br>Three vertical pieces and four horizontal pieces in each leaf                       |
|                  | Astragal                                                                                         | 1.0 mm Galvanized Steel                                                                                                                 |
| Frame            | Nominal Size                                                                                     | 2200 mm wide by 2300 mm high                                                                                                            |
|                  | Material                                                                                         | 1.5 mm Galvanized Steel                                                                                                                 |
| Hardware         | Lock                                                                                             | Mortise lock, Model: 6072N<br>Lock case size: 165 mm x 85 mm x 13 mm,<br>Backset: 60 mm, Latch throw: 10 mm<br>Latch operation: engaged |
|                  | Hinge                                                                                            | Steel hinge<br>Size: 101.5 mm x 97 mm x 3 mm, Quality: 3 for each leaf                                                                  |
| Intumescent Seal | Model: FPJ-A-24/15*2<br>Location: All around the door edges and under the astragal on push side. |                                                                                                                                         |

The sample ID number is S140829012SHJ-001.

The drawings of the Double Leaves Swing Steel Fire Door Assembly, hardware and test wall construction can be found in Appendices A, B, and C respectively. A comprehensive description of the Double Leaves Swing Steel Fire Door Assembly for certification is maintained on Intertek file.

---

## **4 Testing and Evaluation Methods**

---

The test was conducted in accordance with BS 476-22:1987, and BS 476-20:1987.

The test assembly was installed in a steel restraint frame. The test samples were moved in front of the furnace for the fire exposure. The test door was oriented to open away from the furnace, and was built into a concrete masonry unit partition, with fully mortared joints. The nominal dimensions of the test wall were 3 m high by 3 m wide. The test measurement data was shown in Appendix D.

After positioning the assembly frame over the furnace opening, the burners were ignited and the timer was started. Temperatures within the furnace were monitored using thermocouples and the data was recorded. The burners were controlled to keep the furnace temperatures within the allowable limits specified in the test standards. After 5 minutes, the furnace pressure was adjusted so that the neutral plane was established at a maximum of 1000 mm above notional floor level. Periodic observations were made of the surfaces of the test assembly during the fire resistance test.

Door deflection relative to the frame, where applicable, was monitored throughout the test. Position for measurement of deflection and unexposed temperature was presented in the drawing of Appendix D.

## **5 Testing and Evaluation Results**

---

### **5.1. INTEGRITY**

The assembly withstood the fire resistance test without passage of flame or gases hot enough to ignite cotton waste for 165 minutes. No through openings or penetrations were evident at this 165 minutes fire exposure portion of the test and the door latch remained engaged to the strike. During this 165 minutes fire exposure period no significant flaming was observed on the unexposed face of the assembly.

After exposed to the fire for a period of 165 minutes, sustained flame appeared at the area around the meeting edges, integrity failure was deemed to occur. This assembly therefore met the criteria of the test standards for integrity performance of 165 minutes.

### **5.2. INSULATION**

Transmission of heat through the assembly during the fire resistance test of 32 minutes did not raise the average temperature on the unexposed surface by more than 140°C above its initial value, and did not raise the maximum temperature on the unexposed surface by more than 180°C above the initial mean unexposed face temperature. After exposed to the fire for 32 minutes, the maximum temperature on the unexposed surface raise by more than 180°C above its initial value, insulation failure was deemed to occur.

The assembly passed the insulation portion of the test of 32 minutes. A full set of test data is included in Appendix E, and photographs have been presented in Appendix F.

---

## 6 Conclusion

---

The Double Leaves Swing Steel Fire Door Assembly identified in this report has been tested in accordance with BS 476-22:1987 "Fire Tests on Building Materials and Structures – Part 22: Methods for Determination of the Fire Resistance of Non-loadbearing Elements of Construction, Section 6: Determination of the Fire Resistance of Fully Insulated Doorsets and Shutter Assemblies".

The test assembly satisfied the performance requirements for the following periods:

|                   |                   |             |
|-------------------|-------------------|-------------|
| <b>Integrity</b>  | Sustained flaming | 165 minutes |
|                   | Gap gauge         | 165 minutes |
|                   | Cotton pad        | 165 minutes |
| <b>Insulation</b> |                   | 32 minutes  |

The test was discontinued after a period of 180 minutes at the request of the sponsor.


The conclusions of this test report may be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.

### INTERTEK


  
Reported by: \_\_\_\_\_  
Ping Rao  
Project Engineer, Building Products

  
Reviewed by: \_\_\_\_\_  
Harrison Li  
Senior Project Engineer, Building Products


---




8     **Appendix B: Hardware Drawings**




Hinge



## 9 Appendix C: Test Wall Construction Drawing




## 10 Appendix D: Test Measurement Data




UNEXPOSED SIDE

DOOR ASSEMBLY INITIAL CLEARANCES



POSITION FOR MEASUREMENT OF HORIZONTAL DEFLECTION



POSITION FOR MEASUREMENT OF UNEXPOSED TEMPERATURE

## 11 Appendix E: Test Data



Reviewer: Harrison Li

Test: Fire Resistance  
Test Date: 2014.11.24  
Job No: 140829012SHJ-BP  
Client: ZHEJIANG JIAHUI DOORS CO., LTD.  
Sample: Double Leaf Swing Steel Fire Door Assembly  
Sample ID: S140829012SHJ-1

Eng/Tech: Ping Rao

Standards: BS476-22:1987 Part 22: Methods for determination of the fire resistance of non-loadbearing elements of construction

Procedure: According to BS 476-22, Section 6, 7, 8

Conditioning: According to BS 476-20, Section 4.6

Equipment:

| <i>Item</i>               | <i>ID</i>    | <i>Cal Due Date</i> |
|---------------------------|--------------|---------------------|
| Vertical furnace          | SH1097       | 2015.4.28           |
| Furnace pressure gauge    | SH1097-15    | 2015.8.16           |
| Test Clock                | SH1042       | 2015.8.11           |
| Furnace thermocouple      | SH1097-7~9   | 2015.4.10           |
| Ambient temperature gauge | SH1097-11    | 2015.4.19           |
| Unexposed thermocouple    | SH1097-12~14 | 2015.4.10           |
| Clearance Measurements    | SH1061       | 2016.2.27           |
| Displacement Measurements | SH1034       | 2015.8.5            |

Heating Conditions: According to BS 476-20, Section 3.1

Pressure Conditions: According to BS 476-20, Section 3.2

Ambient Conditions: 5~35°C according to BS 476-20, Section 3.3

Test Specimen: According to BS 476-22, Section 6.2, 7.2, 8.2

Installation of test specimen: According to BS 476-22, Section 6.3, 7.3, 8.3

Furnace Thermocouples: According to BS 476-22, Section 6.4.3, 7.4.3, 8.4.3

Unexposed Face: According to BS 476-22, Section 6.4.5, 7.4.5, 8.4.5

Thermocouple Pads: Length and width 30 mm, thickness  $2.0 \pm 0.5$  mm, dry density  $900 \pm 90$  kg/m<sup>3</sup>, thermal conductivity of  $0.13 \text{ W/(m}^{\circ}\text{K)} \pm 10\%$  at 100 °C

Pressure Measurements: According to BS 476-22, Section 6.4.4, 7.4.4, 8.4.4

Deflection Measurements: According to BS 476-22, Section 6.4.7, 7.4.7, 8.4.7

Test Procedure: According to BS 476-22, Section 6.5, 7.5, 8.5



Reviewer: Harrison Li

Test: Fire Resistance  
Test Date: 2014.11.24  
Job No: 140829012SHJ-BP  
Client: ZHEJIANG JIAHUI DOORS CO., LTD.  
Sample: Double Leaf Swing Steel Fire Door Assembly  
Sample ID: S140829012SHJ-1

Eng/Tech: Ping Rao

Standards: BS476-22:1987 Part 22: Methods for determination of the fire resistance of non-loadbearing elements of construction

Procedure: According to BS 476-22, Section 6, 7, 8

Performance

Criteria: According to BS 476-22, Section 6.6, 7.6, 8.6

1) Integrity: Cotton pad  
Gap gauges  
Sustained flaming

| Time<br>(min'sec") | Cotton Pad<br>Check | 6mm Gap<br>Gauge<br>Distance<br>(mm) | 25mm<br>Gap<br>Gauge<br>"Pass<br>Through" | Performance Observations                                                                             |
|--------------------|---------------------|--------------------------------------|-------------------------------------------|------------------------------------------------------------------------------------------------------|
| Initial            | --                  | 0                                    | No "Pass<br>Through"                      | The test commences.                                                                                  |
| 4'10"              | --                  | 0                                    | No "Pass<br>Through"                      | Light smoke is observed at the middle joint of the door leaf.                                        |
| 6'33"              | --                  | 0                                    | No "Pass<br>Through"                      | Popping sounds from the door.                                                                        |
| 19'15"             | --                  | 0                                    | No "Pass<br>Through"                      | Smoke is evident at the vertical and horizontal edges, and the middle joint of the door leaf.        |
| 30'28"             | --                  | 0                                    | No "Pass<br>Through"                      | Discolouration at the hinge position turning into black in appearance.                               |
| 64'41"             | No ignition         | 0                                    | No "Pass<br>Through"                      | A cotton pad integrity test is performed at the middle joint, the pad is not ignited.                |
| 109'33"            | --                  | 0                                    | No "Pass<br>Through"                      | Smoke issues from the latch position.                                                                |
| 165'0"             | --                  | 0                                    | No "Pass<br>Through"                      | Sustained flames issue from the middle joint of the door leaf. Integrity failure is deemed to occur. |
| 180'0"             | --                  | 0                                    | No "Pass<br>Through"                      | The furnace is extinguished.                                                                         |
| Requirement        | No ignition         | <150                                 | No "Pass<br>Through"                      | No excessive openings, sustained flaming, etc.                                                       |



Reviewer: Harrison Li

Test: Fire Resistance  
Test Date: 2014.11.24  
Job No: 140829012SHJ-BP  
Client: ZHEJIANG JIAHUI DOORS CO., LTD.  
Sample: Double Leaf Swing Steel Fire Door Assembly  
Sample ID: S140829012SHJ-1

Eng/Tech: Ping Rao

Standards: BS476-22:1987 Part 22: Methods for determination of the fire resistance of non-loadbearing elements of construction

Procedure: According to BS 476-22, Section 6, 7, 8

Performance

Criteria: According to BS 476-20, Section 10.4

2) Insulation: Mean temperature rise 140°C according to BS 476-20, Section 10.4. Maximum temperature rise 180°C according to BS 476-20, Section 10.4.

| Time(Minutes)         | Ambient (°C) | T1 (°C) | T2 (°C) | T3 (°C) | T4 (°C) | T5 (°C) | T6 (°C) | T7 (°C) | T8 (°C) |
|-----------------------|--------------|---------|---------|---------|---------|---------|---------|---------|---------|
| Initial               | 20           | 20      | 18      | 19      | 19      | 20      | 20      | 17      | 19      |
| 1                     | 20           | 20      | 19      | 19      | 19      | 20      | 20      | 17      | 19      |
| 2                     | 20           | 21      | 18      | 19      | 19      | 20      | 20      | 19      | 20      |
| 3                     | 20           | 22      | 21      | 20      | 20      | 20      | 20      | 31      | 20      |
| 4                     | 20           | 24      | 20      | 20      | 20      | 20      | 22      | 41      | 21      |
| 5                     | 20           | 25      | 19      | 19      | 19      | 20      | 23      | 53      | 22      |
| 6                     | 20           | 27      | 18      | 20      | 20      | 20      | 25      | 62      | 23      |
| 7                     | 20           | 30      | 18      | 20      | 20      | 20      | 28      | 68      | 25      |
| 8                     | 20           | 33      | 18      | 20      | 20      | 20      | 31      | 73      | 29      |
| 9                     | 20           | 37      | 19      | 20      | 20      | 20      | 34      | 78      | 32      |
| 10                    | 20           | 42      | 19      | 20      | 20      | 20      | 39      | 84      | 36      |
| 11                    | 20           | 49      | 19      | 20      | 20      | 21      | 52      | 91      | 50      |
| 12                    | 20           | 55      | 19      | 20      | 21      | 21      | 73      | 99      | 70      |
| 13                    | 20           | 60      | 20      | 21      | 22      | 21      | 90      | 107     | 86      |
| 14                    | 20           | 65      | 20      | 21      | 22      | 22      | 94      | 110     | 92      |
| 15                    | 20           | 69      | 21      | 22      | 23      | 22      | 98      | 114     | 100     |
| 16                    | 20           | 73      | 21      | 23      | 23      | 23      | 99      | 116     | 101     |
| 17                    | 20           | 79      | 23      | 24      | 23      | 24      | 98      | 119     | 102     |
| 18                    | 20           | 85      | 24      | 25      | 24      | 24      | 100     | 122     | 100     |
| 19                    | 20           | 92      | 25      | 26      | 25      | 26      | 98      | 124     | 101     |
| 20                    | 20           | 100     | 27      | 27      | 26      | 27      | 98      | 127     | 100     |
| 21                    | 20           | 114     | 28      | 29      | 28      | 28      | 101     | 131     | 106     |
| 22                    | 20           | 126     | 30      | 31      | 30      | 30      | 104     | 135     | 114     |
| 23                    | 20           | 136     | 31      | 33      | 32      | 33      | 108     | 140     | 118     |
| 24                    | 20           | 142     | 33      | 36      | 36      | 37      | 110     | 146     | 120     |
| 25                    | 20           | 148     | 36      | 39      | 40      | 40      | 115     | 155     | 126     |
| 26                    | 20           | 153     | 38      | 42      | 43      | 45      | 118     | 162     | 138     |
| 27                    | 20           | 160     | 41      | 48      | 50      | 52      | 120     | 166     | 143     |
| 28                    | 20           | 170     | 43      | 52      | 55      | 68      | 122     | 168     | 148     |
| 29                    | 20           | 176     | 46      | 57      | 67      | 84      | 126     | 169     | 152     |
| 30                    | 20           | 184     | 54      | 62      | 75      | 88      | 97      | 171     | 160     |
| 31                    | 20           | 191     | 60      | 67      | 83      | 89      | 111     | 171     | 162     |
| 32                    | 20           | 195     | 66      | 73      | 86      | 90      | 127     | 174     | 164     |
| 33                    | 20           | 200     | 70      | 78      | 89      | 90      | 141     | 224     | 165     |
| 34                    | 20           | 207     | 78      | 83      | 88      | 90      | 146     | 225     | 167     |
| 35                    | 20           | 213     | 84      | 88      | 89      | 90      | 150     | 228     | 168     |
| Temperature Rise (°C) |              | 194     | 65      | 69      | 70      | 71      | 131     | 209     | 149     |

Average temperature rise at 35 min 94 °C  
Maximum temperature rise at 35 min 194 °C  
Maximum temperature rise at 35 min (Frame) 209 °C



Reviewer: Harrison Li

Test: Fire Resistance  
Test Date: 2014.11.24  
Job No: 140829012SHJ-BP  
Client: ZHEJIANG JIAHUI DOORS CO., LTD.  
Sample: Double Leaf Swing Steel Fire Door Assembly  
Sample ID: S140829012SHJ-1

Eng/Tech: Ping Rao

Standards: BS476-22:1987 Part 22: Methods for determination of the fire resistance of non-loadbearing elements of construction

Procedure: According to BS 476-22, Section 6, 7, 8

| Time(Minutes) | Maximum perpendicular displacement where a positive measurement indicates movement towards the furnace (mm) |    |    |    |    |     |    |
|---------------|-------------------------------------------------------------------------------------------------------------|----|----|----|----|-----|----|
|               | D1                                                                                                          | D2 | D3 | D4 | D5 | D6  | D7 |
| Initial       | 0                                                                                                           | 0  | 0  | 0  | 0  | 0   | 0  |
| 10            | 3                                                                                                           | 4  | 22 | 19 | 0  | -7  | 4  |
| 20            | 3                                                                                                           | 1  | 32 | 30 | 0  | -7  | 2  |
| 30            | -1                                                                                                          | -3 | 43 | 43 | 0  | -15 | 6  |
| 40            | -4                                                                                                          | -4 | 57 | 56 | 0  | -16 | 9  |
| 50            | -4                                                                                                          | 4  | 67 | 65 | 0  | -16 | 0  |
| 60            | -5                                                                                                          | -4 | 77 | 80 | 0  | -21 | 4  |
| 70            | -3                                                                                                          | -9 | 79 | 79 | 0  | -21 | 4  |
| 80            | -4                                                                                                          | 1  | 82 | 83 | 0  | -23 | 1  |
| 90            | -5                                                                                                          | -6 | 78 | 78 | 0  | -25 | 0  |
| 100           | -5                                                                                                          | -6 | 76 | 76 | 0  | -27 | -1 |
| 120           | -2                                                                                                          | -6 | 68 | 81 | 0  | -29 | 1  |
| 135           | -5                                                                                                          | -6 | 84 | 82 | 0  | -31 | 0  |
| 150           | -4                                                                                                          | -8 | 83 | 83 | 0  | -30 | -1 |
| 165           | -5                                                                                                          | -9 | 82 | 83 | 0  | -31 | -3 |


| Time(Minutes) | Maximum perpendicular displacement where a positive measurement indicates movement towards the furnace (mm) |    |     |     |
|---------------|-------------------------------------------------------------------------------------------------------------|----|-----|-----|
|               | D8                                                                                                          | D9 | D10 | D11 |
| Initial       | 0                                                                                                           | 0  | 0   | 0   |
| 10            | 6                                                                                                           | 5  | 4   | -4  |
| 20            | 9                                                                                                           | 5  | 8   | -5  |
| 30            | 10                                                                                                          | 7  | 8   | -6  |
| 40            | 7                                                                                                           | 7  | 8   | -4  |
| 50            | 5                                                                                                           | 5  | 8   | -6  |
| 60            | 5                                                                                                           | 5  | 10  | -12 |
| 70            | 6                                                                                                           | 3  | 11  | -9  |
| 80            | 5                                                                                                           | 0  | 8   | -14 |
| 90            | -26                                                                                                         | 1  | 8   | -14 |
| 100           | -27                                                                                                         | 2  | 8   | -16 |
| 120           | -9                                                                                                          | -1 | 6   | -15 |
| 135           | 3                                                                                                           | 2  | 7   | -16 |
| 150           | 1                                                                                                           | 1  | 4   | -18 |
| 165           | 0                                                                                                           | -3 | 3   | -14 |



Test: Fire Resistance  
Test Date: 2014.11.24  
Job No: 140829012SHJ-BP  
Client: ZHEJIANG JIAHUI DOORS CO., LTD.  
Sample: Double Leaf Swing Steel Fire Door Assembly  
Sample ID: S140829012SHJ-1  
Standards: BS476-22:1987 Part 22: Methods for determination of the fire resistance of non-loadbearing elements of construction  
Procedure: According to BS 476-22, Section 6, 7, 8  
Measurement of Furnace  
Conditions: Pressure and temperature according to BS 476-20, Section 3

Reviewer: Harrison Li

Eng/Tech: Ping Rao



## 12 Appendix F: Test Photographs

---



Fig. 1 – Exposed Side Prior to the Fire Test



Fig. 2 – Unexposed Side Prior to the Fire Test

---



Fig. 3 – Unexposed Side after 20 Minutes



Fig. 4 – Unexposed Side after 40 Minutes



Fig. 5 – Unexposed Side after 60 Minutes



Fig. 6 – Unexposed Side after 107 Minutes



Fig. 7 – Unexposed Side after 150 Minutes




Fig. 8 – Unexposed Side after 165 Minutes

---

## 13 Revision Page

---

| Revision No. | Date             | Changes     | Author   | Reviewer    |
|--------------|------------------|-------------|----------|-------------|
| 0            | December 1, 2014 | First issue | Ping Rao | Harrison Li |
|              |                  |             |          |             |
|              |                  |             |          |             |

END OF DOCUMENT

---